




LOAD REQUIREMENTS	
DISTRIBUTED LATERAL LOAD	25 kN/m ²
TOP SLAB DISTRIBUTED LOAD	60 kN/m ²
TOP SLAB POINT LOAD	70 kN




CROSS SECTION 'B'



PLAN VIEW



ISOMETRIC VIEW



CROSS SECTION 'A'

Ø127mm [5] (TYP.)
POLYLOK PIPESEAL
12 PER SIDE

- NOTES:**
- SOIL BEARING CAPACITY TO BE MIN. 345kPa (SLS) OR USE A CONCRETE BASE PAD; VERIFY ON SITE.
 - SEISMIC ANCHORAGE FROM EQUIPMENT TO PAD AND PAD TO BASE TO BE PROVIDED BY OTHERS.

mm
[Inches]
ALL DIMENSIONS DEFAULT TO MILLIMETRES



UTILITY STRUCTURES INC.
61 BONGARD AVE | OTTAWA, ON | K2E 6V2
T: 613.225.6398 F: 613.225.1681 TF: 800.267.6466
www.utilitystructures.com

- CONSTRUCTION DETAILS:**
- REFERENCE **HYDRO ONE DU-09-403**
 - CSA 23.4-05
 - 35 MPa (5000psi) AT 28 DAYS
 - STRIPPING STRENGTH: MIN. 20 MPa(2900psi)
 - 5-8% AIR ENTRAINED
 - EXPOSURE CLASS: C-1
 - REINFORCING: STEEL TO CSA CAN A23.1

- PRODUCT DETAILS:**
- (4) 127mm[5"] POLYLOK PIPESEAL WINDOWS (6 POLYLOKS PER WINDOW)
 - THREE PHASE PAD-MOUNTEDSWITCGEAR (4 WAY) TRANSFORMER BASE
 - USE WITH **E-14A, E-14AK OR E-14 (403)** TRANSFORMER PAD
 - CUSTOM OPTIONS AVAILABLE:
 - CUSTOM WINDOWS & OPENINGS

PRODUCT CODE:	
<h1>E-14</h1>	
THREE PHASE TRANSFORMER BASE	
OUTSIDE DIMENSIONS:	
1.07m(H) X 1580mm x 1900mm	
TOTAL WEIGHT:	
1,700 kg / 3,740 lbs	
REVISION DATE:	REV. # 4
MARCH 15, 2016	