




**CROSS SECTION 'B'**



**PLAN VIEW**



**ISOMETRIC VIEW**



**CROSS SECTION 'A'**

mm  
[Inches]  
ALL DIMENSIONS DEFAULT TO MILLIMETRES



**UTILITY STRUCTURES INC.**

61 BONGARD AVE | OTTAWA, ON | K2E 6V2  
T: 613.225.6398 F: 613.225.1681 TF: 800.267.6466

[www.utilitystructures.com](http://www.utilitystructures.com)

**CONSTRUCTION DETAILS:**

• AS PER [HYDRO ONE DU-09-101](#) & [DU-09-201](#)

• **CSA 23.4-05**

- 35 MPa (5000psi) AT 28 DAYS
- STRIPPING STRENGTH: MIN. 20 MPa(2900psi)
- 5-8% AIR ENTRAINED
- EXPOSURE CLASS: F-1
- REINFORCING: STEEL TO CSA CAN A23.1

**PRODUCT DETAILS:**

- (2) 127mm[5"] POLYLOK PIPESEAL WINDOWS (12 POLYLOKS PER WINDOW)
- (2) 127mm[5"] POLYLOK PIPESEAL WINDOWS (8 POLYLOKS PER WINDOW)
- SINGLE PHASE BASE 25kVA TO 167kVA

**PRODUCT CODE:**

**E-15-PC**

SINGLE PHASE TRANSFORMER BASE

**OUTSIDE DIMENSIONS:**

**1.07m(H) X 1016mm x 1473mm**

**TOTAL WEIGHT:**

**1,600 kg / 3,500 lbs**

**REVISION DATE:**

**FEBRUARY 4, 2015**

**REV. # 3**