



**PLAN VIEW**



**CROSS SECTION 'A-A'**



**ISOMETRIC VIEW**

mm  
[inches]  
ALL DIMENSIONS DEFAULT TO MILLIMETRES



**UTILITY STRUCTURES INC.**

61 BONGARD AVE | OTTAWA, ON | K2E 6V2  
T: 613.225.6398 F: 613.225.1681 TF: 800.267.6466

[www.utilitystructures.com](http://www.utilitystructures.com)

**CONSTRUCTION DETAILS:**

- **FRAME AND COVER CAST IN**
  - AS PER CITY OF TORONTO 802.005
  - AS PER CITY OF TORONTO 802.006
- **CSA 23.4-05**
  - 35 MPa (5000psi) AT 28 DAYS
  - STRIPPING STRENGTH: MIN. 20 MPa(2900psi)
  - 5-8% AIR ENTRAINED
  - EXPOSURE CLASS: C-1
  - REINFORCING: STEEL TO CSA CAN A23.1

**PRODUCT CODE:**

**E-32M**

ELECTRICAL HANDHOLE

**DIMENSIONS:**

**1.1m(H) x 460mm DIA.**

**TOTAL WEIGHT:**

**355 kg / 780 lbs**

**REVISION DATE:**

**SEPTEMBER 11, 2017**

**REV. # 3**